
A MEMBER OF THE STOHL GROUP OF COMPANIES

November 10, 2016

Mr. David Flaherty
Randolph Central School District
Head Custodian
18 Main Street
Randolph, New York 14772

re: Lead Testing in School Drinking Water

Dear Mr. Flaherty:

This letter is provided by Stohl Environmental LLC and includes results of Lead Testing in School Drinking Water for the following educational building(s):

- Randolph High School

This letter is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The collection of water samples was performed by School District staff on 9/23/2016 following the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools". The water samples were then delivered by the School District to Stohl Environmental following strict chain-of-custody protocols. Once received, the water samples were then transmitted by Stohl Environmental to an independent laboratory approved by the NYS Department of Health's Environmental Laboratory Approval Program (ELAP) following strict chain-of-custody protocols.

As detailed below, based on the laboratory results, sixteen (16) sources of potable water in Randolph High School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions are required by the District as identified below.

Laboratory reports and Chain of Custody forms are included as attachments to this letter.

A MEMBER OF THE STOHL GROUP OF COMPANIES

Summary of Sampling and Analysis

Total Number of Samples Collected by Building Classified by First Draw:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples	
			Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Randolph High School	9/23/2016	146	130	16

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples				
Sample #	Sample Type	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
H16	First Draw	113	Sink 3	19.5
H65	First Draw	220	Sink 2	15.9
H67	First Draw	220A	Sink	73.5
H68	First Draw	221	Sink 1	25.6
H71	First Draw	221	Sink 4	43.2
H74	First Draw	222	Sink 1	111
H87	First Draw	222	Sink 14	24.6
H88	First Draw	223	Sink	41.1
H89	First Draw	224	Sink 1	87.5
H90	First Draw	224	Sink 2	71.0
H91	First Draw	224	Sink 3	66.0
H92	First Draw	224	Sink 4	67.2
H93	First Draw	224	Sink 5	69.2
H94	First Draw	224	Sink 6	152
H96	First Draw	224	Sink 7	65.6
H97	First Draw	224	Sink 8	25.2

A MEMBER OF THE STOHL GROUP OF COMPANIES


Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

Thank you for the opportunity to be of service to Randolph Central School District.

Sincerely,
Stohl Environmental, LLC.



William K. Sisco
Senior Project Manager



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway
Buffalo, New York 14219
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

Laboratory Analytical Reports



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway
Buffalo, New York 14219
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

Chains of Custody